

RESEARCH-DEVELOPMENT AND TESTING NATIONAL INSTITUTE FOR ELECTRICAL ENGINEERING

ICMET CRAIOVA HIGH POWER DIVISION

HIGH POWER LABORATORY "Ovidiu Rarinca"

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA Matriculation certificate: J16/312/1999, VAT number RO387 1599 Phone: (351) 402 427; Fax: (251) 415482; (351) 404 890;

E-mail: Imp@icmet.ro

acreditat pentru ÎNCERCARE



SR EN ISO/CEI 17025:2005 CERTIFICAT DE ACREDITARE pr. 1.1.004/2010

TEST REPORT No. 11473

CUSTOMER:

PERSIS ELECTRIC

No.10, Eftekhar Alley, Larestan Ave., Motahari, Tehran - Iran

MANUFACTURER: PERSIS ELECTRIC

No.10, Eftekhar Alley, Larestan Ave., Motahari, Tehran - Iran

TESTED

24 kV, 1250 A, 25 kA Metal Clad Cubicle

PRODUCT:

with withdrawable Vacuum Circuit Breaker

REFERENCE

IEC 62271-200/2003, clause 6.101

STANDARD:

IEC 62271-100/2008, clauses 6.106

TEST

Basic short-circuit test-duties: T10, T30, T60, T100s and T100a

PERFORMED:

TEST DATE:

13-14.06.2012

TEST RESULT:

Passed the tests

Test Report has 31 pages and it is edited in 4 copies from which copy 1 for laboratory and copies 2, 3 and 4 for customer.

HEAD OF HIGH POWER DIVISION:

CRAIOVA

HEAD OF LABORATORY:

Eng. Constantin Iancu

DATE OF ISSUE:

01.08.2012

Dr. Eng. George Curcanu

^{1.} Results refer to test product only.

^{2.} Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to.

^{3.} Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.

[©] ICMET Craiova 2012/IM



RESEARCH-DEVELOPMENT AND TESTING NATIONAL INSTITUTE FOR ELECTRICAL ENGINEERING

ICMET CRAIOVA HIGH POWER DIVISION

HIGH POWER LABORATORY

"Ovidiu Rarinca"

200746-CRAIOVA, Blvd. DECEBAL No. 118A, ROMANIA Matriculation certificate: J16/312/1999, VAT number RO387 1599 Phone: (351) 402 427; Fax: (251) 415482; (351) 404 890;

E-mail: Imp@icmet.ro



TEST REPORT No. 11475

CUSTOMER:

PERSIS ELECTRIC

No.10, Eftekhar Alley, Larestan Ave., Motahari, Tehran - Iran

MANUFACTURER: PERSIS ELECTRIC

No. 10, Eftekhar Alley, Larestan Ave., Motahari, Tehran - Iran

TESTED

24 kV, 1250 A, 25 kA Metal Clad Cubicle with withdrawable Vacuum Circuit Breaker

PRODUCT:

with withdrawable vacuum cheuit Bre

REFERENCE STANDARD: IEC 62271-200/2003, clause 6.6

TEST

Short-time withstand current and peak withstand current test

PERFORMED:

on main circuit

TEST DATE:

14.06.2012

TEST RESULT:

Passed the test

Test Report has 16 pages and it is edited in 4 copies from which copy 1 for laboratory and copies 2, 3 and 4 for customer

HEAD OF HIGH POWER DIVISION:

Dr. Eng. George Curcane MET

HEAD OF LABORATORY: Eng. Constantin Iancu

/LABORATORUL
DE MARE PUTERE
"OVIDIL BARINGA"

CRAIOVA

DATE OF ISSUE:

ISSUE: 02.08.2012

^{1.} Results refer to test product only.

^{2.} Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to.

^{3.}Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.

[©] ICMET Craiova 2011/IM



RESEARCH-DEVELOPMENT AND TESTING NATIONAL INSTITUTE FOR ELECTRICAL ENGINEERING

ICMET CRAIOVA HIGH POWER DIVISION

HIGH POWER LABORATORY "Ovidiu Rarinca"

200746 CRAIOVA, Blvd. DECEBAL, No.118A, ROMANIA Matriculation certificate: J16/312/1999, VAT number RO387 1599 Phone: (351) 402 427; Fax: (251) 415482; (351) 404 890;

E-mail: Imp@icmet.ro

acreditat pentru ÎNCERCARE



SR EN ISO/CEI 17025:2005 CERTIFICAT DE ACREDITARE nr. LI 004/2010

TEST REPORT No. 11479

CUSTOMER:

PERSIS ELECTRIC

No.10, Eftekhar Alley, Larestan Ave., Motahari, Tehran - Iran

MANUFACTURER: PERSIS ELECTRIC

No.10, Eftekhar Alley, Larestan Ave., Motahari, Tehran - Iran

TESTED

24 kV, 1250 A, 25 kA Metal Clad Cubicle

PRODUCT:

with withdrawable Vacuum Circuit Breaker

REFERENCE STANDARD:

IEC 62271-200/2011 clause 6.106

TEST

Internal arc test in:

PERFORMED:

- bus-bars compartment

- circuit breakers compartment

- cables compartment

TEST DATE:

18.06.2012

TEST RESULT:

Passed the tests

Report has 21 pages and it is edited in 4 copies from which copy 1 for laboratory and copies 2, 3 and 4 for customer.

HEAD OF HIGH/POWER DIVISION:

HEAD OF LABORATORY:

Eng. Constantin Iancu

Dr. Eng. George Gurcanu

LABORATORUL DE MARE PUTERE "OVIDIU RARINCA"

DATE OF ISSUE: A02.08.2012

1. Results refer to test product only.

2. Publication or reproduction of the contents of this report in any other form unless its complete photocopying is not allowed without writing approval of division to which laboratory belongs to.

3.Accreditation of the laboratory or any of its Test Reports issued under accreditation regime do not constitute or do not imply themselves an approval of the product by the accreditation body.

© ICMET Craiova 2012/IM